

EXTRA; EXTRA; READ ALL ABOUT IT!

Effective January 1st, 2011



New for the North Carolina Residential Building Code are **Carbon Monoxide Alarms** for One and Two Family Dwellings. Along with your traditional Smoke Alarms, Carbon Monoxide Alarms shall be installed where required by code as listed below.

R313.1.1 Carbon monoxide alarms. In new construction, dwelling units shall be provided with an approved carbon monoxide alarm installed outside of each separate sleeping area in the immediate vicinity of the bedroom(s).

R313.1.2 Where required-existing dwellings. In existing dwellings, where interior alterations, repairs, fuel-fired appliance replacements, or additions requiring a permit occurs, or where one or more sleeping rooms are added or created, carbon monoxide alarms shall be provided in accordance with Section 313.1.1.

R313.1.3 Alarm requirements. The required carbon monoxide alarms shall be clearly audible in all bedrooms over background noise levels with all intervening doors closed. Single station carbon monoxide alarms shall be listed as complying with UL 2034 structures.